

# CITY OF PASCO INSPECTION NOTICE



City of  
**Pasco**

## Type of Inspection

- |  |   |
|--|---|
| <input type="checkbox"/> Footing/Setback | <input type="checkbox"/> Mech/Gas         |
| <input type="checkbox"/> Stemwall        | <input checked="" type="checkbox"/> Frame |
| <input type="checkbox"/> Water/Sewer     | <input type="checkbox"/> Insulation       |
| <input type="checkbox"/> U.G. Plumb      | <input type="checkbox"/> Sheetrock        |
| <input type="checkbox"/> Shearwall       | <input type="checkbox"/> Final            |
| <input type="checkbox"/> Rough Plumb     | <input type="checkbox"/> Other _____      |

## Correction Notice

Job Located 8509 ASHEN

Owner \_\_\_\_\_

Permit B24-0604

Inspection of your work revealed that the following is not in  
accordance with the codes governing the work in this jurisdiction:

- 1) OBTAIN L&I COVER APPROVAL
- 2) FOAM SEAL PENETRATIONS

These corrections must be made and are **not to be covered** until reinspection is made and approved under current building codes. When **all** corrections have been made, please call **545-3442** to schedule a reinspection.

Date 5-30-24

  
INSPECTOR