

CITY OF PASCO INSPECTION NOTICE



Correction Notice

Type of Inspection

- | | |
|--|---|
| <input type="checkbox"/> Footing/Setback | <input type="checkbox"/> Mech/Gas |
| <input type="checkbox"/> Stemwall | <input type="checkbox"/> Frame |
| <input type="checkbox"/> Water/Sewer | <input type="checkbox"/> Insulation |
| <input type="checkbox"/> U.G. Plumb | <input type="checkbox"/> Sheetrock |
| <input type="checkbox"/> Shearwall | <input checked="" type="checkbox"/> Final |
| <input type="checkbox"/> Rough Plumb | <input type="checkbox"/> Other _____ |

Job Located 12002 DUNSMUR
Owner _____
Permit _____

Inspection of your work revealed that the following is not in accordance with the codes governing the work in this jurisdiction:

- 1) OBTAIN L&I FINAL APPROVAL
- 2) WA STATE ENERGY COMPLIANCE FORM MUST BE 100% FILLED OUT - MISSING BLOWER DOOR TEST RESULTS
- 3) PROVIDE BLOWER DOOR TEST RESULTS
- 4) CITY APPROVED PLANS MUST BE ON SITE AT FINAL

These corrections must be made and are **not to be covered** until reinspection is made and approved under current building codes. When **all** corrections have been made, please call **545-3442** to schedule a reinspection.

Date 9-11-21 _____
INSPECTOR