

# CITY OF PASCO INSPECTION NOTICE



City of  
**Pasco**

## Type of Inspection

- |   |  |
|---|--|
| <input type="checkbox"/> Footing/Setback        | <input checked="" type="checkbox"/> Mech/Gas |
| <input type="checkbox"/> Stemwall               | <input checked="" type="checkbox"/> Frame    |
| <input type="checkbox"/> Water/Sewer            | <input type="checkbox"/> Insulation          |
| <input type="checkbox"/> U.G. Plumb             | <input type="checkbox"/> Sheetrock           |
| <input checked="" type="checkbox"/> Shearwall   | <input type="checkbox"/> Final               |
| <input checked="" type="checkbox"/> Rough Plumb | <input type="checkbox"/> Other _____         |

## Correction Notice

Job Located 113 S ELM

Owner \_\_\_\_\_

Permit 823-0619

Inspection of your work revealed that the following is not in accordance with the codes governing the work in this jurisdiction:

- 1) ~~ADD TRUSS SCREWS UNDER PATTI ALL~~
- 2) STRAP GARAGE HOOD+R
- 3) TRUSS CLIPS OR SCREWS (ALL)
- 4) WINDOW SILLS MUST BE 44" FOR DRESS
- 5) ADD ATTIC ACCESS

NOT OFFICIAL FRAMEWORK  
INSPECTION

These corrections must be made and are **not to be covered** until reinspection is made and approved under current building codes. When **all** corrections have been made, please call **545-3442** to schedule a reinspection.

Date 8/29/23 DS

INSPECTOR