

CITY OF PASCO INSPECTION NOTICE



City of
Pasco

Type of Inspection

- | | |
|---|--|
| <input type="checkbox"/> Footing/Setback | <input checked="" type="checkbox"/> Mech/Gas |
| <input type="checkbox"/> Stemwall | <input checked="" type="checkbox"/> Frame |
| <input checked="" type="checkbox"/> Water/Sewer | <input type="checkbox"/> Insulation |
| <input type="checkbox"/> U.G. Plumb | <input type="checkbox"/> Sheetrock |
| <input type="checkbox"/> Shearwall | <input type="checkbox"/> Final |
| <input checked="" type="checkbox"/> Rough Plumb | <input type="checkbox"/> Other _____ |

Correction Notice

Job Located 113 S Elm

Owner _____

Permit B23-0619

Inspection of your work revealed that the following is not in accordance with the codes governing the work in this jurisdiction:

- 1) COMPLETE FRAMING ABOVE PANTRY - STUDS OR RAFTERS
- 2) COMPLETE DUCTING FOR EXHAUST FANS & KITCHEN/RANGE EXHAUST
- 3) PROVIDE STRONG BACK BRACE AT 2 GABLES
- 4)

OK TO INSULATE AFTER L&I COVER APPROVAL

These corrections must be made and are **not to be covered** until reinspection is made and approved under current building codes. When **all** corrections have been made, please call **545-3442** to schedule a reinspection.

Date 9-5-23 _____

INSPECTOR