

CITY OF PASCO INSPECTION NOTICE



City of
Pasco

Type of Inspection

- | | |
|--|---|
| <input type="checkbox"/> Footing/Setback | <input type="checkbox"/> Mech/Gas |
| <input type="checkbox"/> Stemwall | <input type="checkbox"/> Frame |
| <input type="checkbox"/> Water/Sewer | <input type="checkbox"/> Insulation |
| <input type="checkbox"/> U.G. Plumb | <input type="checkbox"/> Sheetrock |
| <input type="checkbox"/> Shearwall | <input checked="" type="checkbox"/> Final |
| <input type="checkbox"/> Rough Plumb | <input type="checkbox"/> Other _____ |

Correction Notice

Job Located 113 S Elm

Owner _____

Permit 1523-0619

Inspection of your work revealed that the following is not in accordance with the codes governing the work in this jurisdiction:

- 1) OBTAIN RIGHT OF WAY FINAL APPROVAL
- 2) PROVIDE GRASS COVER AT ALL EXPOSED SOILS (TACKIFIER, SOD, HYDRO SEED)
- 3) REMOVE ALL GARBAGE FROM FRONT YARD
- 4) OBTAIN L & I FINAL APPROVAL
- 5) SET BUMPER HINGES AT GARAGE TO HOUSE DOOR
- 6) PROVIDE PERMANENT LADDER AT CRAWL SPACE ACCESS OVER 44" DEEP
- 7) PROVIDE WA STATE ENERGY COMPLIANCE FORM

These corrections must be made and are **not to be covered** until reinspection is made and approved under current building codes. When **all** corrections have been made, please call **545-3442** to schedule a reinspection.

Date 12-28-23

WS
INSPECTOR