

CITY OF PASCO INSPECTION NOTICE



City of
Pasco

Type of Inspection

- | | |
|--|---|
| <input type="checkbox"/> Footing/Setback | <input checked="" type="checkbox"/> Mech/Gas |
| <input type="checkbox"/> Stemwall | <input type="checkbox"/> Frame |
| <input type="checkbox"/> Water/Sewer | <input type="checkbox"/> Insulation |
| <input type="checkbox"/> U.G. Plumb | <input type="checkbox"/> Sheetrock |
| <input type="checkbox"/> Shearwall | <input type="checkbox"/> Final |
| <input type="checkbox"/> Rough Plumb | <input checked="" type="checkbox"/> Other _____ |

Correction Notice

Job Located

4215 SESOIA DR.

Owner _____

Permit

B23-1194

Inspection of your work revealed that the following is not in accordance with the codes governing the work in this jurisdiction:

①. LINE SET WHERE IT ENTERS UNIT SEEMS TO BE LEAKING AND CREATING AN EXCESSIVE AMOUNT OF CONDENSATION

These corrections must be made and are **not to be covered** until reinspection is made and approved under current building codes. When **all** corrections have been made, please call 545-3442 to schedule a reinspection.

Date

8/9/23

INSPECTOR