

CITY OF PASCO INSPECTION NOTICE



City of
Pasco

Type of Inspection

Correction Notice

- | | |
|--|---|
| <input type="checkbox"/> Footing/Setback | <input type="checkbox"/> Mech/Gas |
| <input type="checkbox"/> Stemwall | <input type="checkbox"/> Frame |
| <input type="checkbox"/> Water/Sewer | <input type="checkbox"/> Insulation |
| <input type="checkbox"/> U.G. Plumb | <input type="checkbox"/> Sheetrock |
| <input type="checkbox"/> Shearwall | <input type="checkbox"/> Final |
| <input type="checkbox"/> Rough Plumb | <input checked="" type="checkbox"/> Other <u>Shed</u> |

Job Located

41204 Sedona DR

Owner

Permit

BZ3-1282

Inspection of your work revealed that the following is not in Accordance with the codes governing the work in this jurisdiction:

1) Bottom cord of rafters needs to be 2x6. (See plans details).

2) Bottom plate anchor bolts needs to be 12" with in each end of the Bottom plate. ~~add~~ ~~anchor~~ ~~bolts~~ (Front entry corners).

3) add another anchor bolt on Right side of shed.

4) provide ~~proof~~ proof of slab footings for shed.

These corrections must be made and are **not to be covered** until reinspection is made and approved under current building codes. When **all** corrections have been made, please call **545-3442** to schedule a reinspection.

Date

9-19-23

SA

INSPECTOR